



SUMMARY TEST REPORT

FOR: Andersen Corporation
100 Fourth Avenue North
Bayport, MN 55003

Report Number: G1239.03-201-44
Test End Date: 08/19/2016
Report Date: 08/29/2016
Test Record Retention End Date: 08/19/2020

SERIES TESTED: Clad Wood Casement Fixed Window
MODEL TESTED: A-Series Casement Window/ACW4080S IG

NAFS-08/-11	Class R-PG40 Size Tested 47.3 x 95.3 in. DP +40/-40
Test	Results Summary
Operating Ease	N/A
Resistance to Air Infiltration	<0.01 cfm/ft ² (ASTM E283)
Resistance to Water Penetration	Pass at DP50 (ASTM E547)
Resistance to Structural Loading	Pass at DP +40/-40 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F 588)

CAN/CSA A440-00 , Evaluation to the prescriptive requirements were not performed	
Test	Rating
Operating Ease	N/A
Air Tightness	Fixed
Water Tightness	B3
Wind Load Resistance	C3
Blow-Out	C3
Forced Entry Resistance	F10

REFERENCE:	See ATI Report No. G1239.01 -201-44, and G1239.02-201-44 for complete test results.
-------------------	---

A copy of this report will be retained by Intertek-ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

INTERTEK-ATI

INTERTEK-ATI

Tony D. Gavin
Technician

Daniel A. Johnson
Director of Regional Operations