

### SUMMARY TEST REPORT

FOR: Andersen Corporation  
100 Fourth Avenue North  
Bayport, Minnesota 55003-1096

Report Number: H6180.02-201-47  
Test End Date: 09/27/2017  
Report Date: 10/04/2017  
Revised Report Date: 08/06/2018  
Test Record Retention End Date: 09/27/2021

SERIES TESTED: Multi-glide Sliding Door  
MODEL TESTED: 3-panel MultiGlide Sliding Door, Pocket Door, Thermal Frame  
**NAFS-08/-11** Class LC PG30 Size Tested 191.0 x 119.5 in. DP +30/30

**Test**

**Results Summary**

Operating Force	Pass, 53 N (12 lbf) max.
Resistance to Air Infiltration	0.16 cfm/ft <sup>2</sup> (ASTM E283)
Resistance to Water Penetration	Pass at DP30 (ASTM E547)
Resistance to Structural Loading	Pass at DP45 (ASTM E330)
Forced Entry Resistance	Pass (ASTM F842)

**REFERENCE:** See Intertek B&C Report No. H6180.01-201-47 for complete test results.

A copy of this report will be retained by Intertek B&C for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**INTERTEK B&C**

**INTERTEK B&C**

Tony D. Gavin  
Technician I

Daniel A. Johnson  
Director - Regional Operations

REVISION #	DATE	PAGES	REVISION
0	10/04/17	N/A	Original Report Issue
1	08/06/18	1	Revised Series/Model name

