



**SUMMARY TEST REPORT**

FOR: Eagle Window & Door, Inc.  
 2045 Kerper Boulevard  
 Dubuque, Iowa 52004

Report Number: C6615.03-201-44  
 Test End Date: 04/15/2013  
 Report Date: 04/15/2013  
 Revised Report Date: 07/09/2013  
 Test Record Retention End Date: 04/15/2017

SERIES TESTED: E-Series Side-Hinged Door (Out-Swing)  
 MODEL TESTED: 6780 Hinged Patio Door – Outswing Double

**NAFS-08,-11** Class LC-PG60 Size Tested 2009 x 2419 mm (79.1 x 95.3 in.)-SHD  
**NAFS-05** SHD-LC60 2009 x 2419 (79 x 95)

**Test**

Operating Ease, Force to Latch  
 Resistance to Air Infiltration  
 Resistance to Water Penetration  
 Resistance to Structural Loading  
 Forced Entry Resistance

**Results Summary**

Pass, 4 lbs  
 0.05 cfm/ft<sup>2</sup> (ASTM E283)  
 Pass at DP60 (ASTM E547)  
 Pass at DP+60/-60 (ASTM E330)  
 Pass (AAMA 1304)

**CAN/CSA A440-00**, Evaluation to the prescriptive requirements were not performed

**Test**

Operating Ease  
 Air Tightness  
 Water Tightness  
 Wind Load Resistance  
 Blow-Out

**Rating**

Pass  
 A3  
 B4  
 C3  
 C3

**Test**

Impact  
 Pressure Cycling

**Results Summary**

N/A  
 N/A

**REFERENCE:**

See ATI Report No. C6615.01-201-44 and C6615.02-201-44  
 for complete test results.

A copy of this report will be retained by ATI for a period of four years. This report is the exclusive property of the client named herein and is applicable to the sample tested. Results obtained are tested values and do not constitute an opinion or endorsement by this laboratory.

**ARCHITECTURAL TESTING, INC**

**ARCHITECTURAL TESTING, INC**

Karl A. Lips-Eakins  
 Senior Technician

Daniel A. Johnson  
 Director of Regional Operations

849 Western Avenue North  
 St. Paul, MN 55117  
 Phone: 651-636-3835  
 Fax: 717-764-4129  
 www.archtest.com