

EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085DL0336


Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EWG)</i>
Distributor <i>Vertreiber</i>	Baxi Calefaccion S.L.U. C/ Lopez de Hoyos, 35 CP, E-28002 Madrid
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Condensing combi water heater optional also as water heater
Model <i>Modell</i>	Platinum iPlus...; Platinum MAX iPlus...
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	supplement test: 20-00564-033 from 26.01.2021 (EBI)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	21-0102-GWR



700218-04-A-DE

09.03.2021 Rie B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-04DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Energy Labelling Energieeffizienzkennzeichnung
Platinum iPlus 24 AF	nominal heat output: 2,8...24,0 kW heat input (Hi): 2,9...24,7 (drinking water: ...28,9) kW	
Platinum iPlus 28 AF	nominal heat output: 3,2...28,0 kW heat input (Hi): 3,3...28,9 (drinking water: ...33,0) kW	
Platinum iPlus 32 AF	nominal heat output: 3,5...32,0 kW heat input (Hi): 3,6...33,0 (drinking water: ...36,0) kW	
Platinum MAX iPlus 24/24 F	nominal heat output: 2,4...20,0 kW heat input (Hi): 2,5...20,6 (drinking water: ...24,7) kW	
Platinum MAX iPlus 30/30 F	nominal heat output: 3,0...24,0 kW heat input (Hi): 3,1...24,7 (drinking water: ...31,0) kW	
Platinum MAX iPlus 35/35 F	nominal heat output: 3,5...32,0 kW heat input (Hi): 3,6...33,0 (drinking water: ...36,0) kW	

