



Number	18GR0250/01	Replaces	18GR0250/00
Issue date	20-04-2022	Contract number	E 6520
Due date	20-04-2032	Module	B (Type testing)
Report number	160301604	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063CR3604		

## EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the condensing central heating boilers, central heating boilers, type(s):

**Remeha Calenta Ace 10DS ,  
Remeha Calenta Ace 10s ,  
Remeha Calenta Ace 15DS,  
Remeha Calenta Ace 15s,  
Remeha Calenta Ace 25DS,  
Remeha Calenta Ace 25L,  
Remeha Calenta Ace 25s,  
Remeha Calenta Ace 28C,  
Remeha Calenta Ace 35C,  
Remeha Calenta Ace 35DS,  
Remeha Calenta Ace 35s,  
Remeha Calenta Ace 40C ,  
Remeha Calenta Ace 40L**

Manufacturer **Remeha B.V.  
Apeldoorn, The Netherlands**

meet(s) the essential requirements as described in the  
**Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.**

Reference standard: EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.



Number	18GR0250/01	Replaces	18GR0250/00
Issue date	20-04-2022	Contract number	E 6520
Due date	20-04-2032	Module	B (Type testing)
Report number	160301604	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063CR3604	Page	1 of 1

## APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

### Manufacturer:

Remeha B.V.

### Types:

Remeha Calenta Ace 10DS , Remeha Calenta Ace 10s , Remeha Calenta Ace 15DS, Remeha Calenta Ace 15s, Remeha Calenta Ace 25DS, Remeha Calenta Ace 25L, Remeha Calenta Ace 25s, Remeha Calenta Ace 28C, Remeha Calenta Ace 35C, Remeha Calenta Ace 35DS, Remeha Calenta Ace 35s, Remeha Calenta Ace 40C , Remeha Calenta Ace 40L

### Appliance types:

B23, B23P, B33, C13(X), C33(X), C43(X), C43P(X), C53(X), C63(X), C83(X), C93(X), C(10)3(X), C(12)3(X)

### Appliance categories:

I2E(S)B, I2E, I2EK, I2ELL, I2Esi, I2H, I2L, I3B/P, I3P, II2ELL3B/P, II2ELwLs3B/P, II2Esi3B/P, II2Esi3P, II2H3B/P, II2H3P, II2HM3B/P, II2HS3B/P, II2L3B/P

### Gas groups and supply pressures:

L: 25 mbar; E: 20 mbar; LL: 20 mbar; H: 20 mbar; 25 mbar; Esi: 20 mbar; 25 mbar; E(S): 20 mbar; M: 20 mbar; Lw: 20 mbar; Ls: 13 mbar; P: 30 mbar; 37 mbar; 50 mbar; B/P: 30 mbar; 37 mbar; 50 mbar

### Countries:

Albania, Algeria, Armenia, Austria, Azerbaijan, Belarus, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Georgia, Germany, Greece, Hungary, Iceland, Ireland, Italy, Kazakhstan, Latvia, Lithuania, Luxembourg, Malta, Moldova, Morocco, Norway, Poland, Portugal, Romania, Russia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Tajikistan, Tunisia, Turkey, Turkmenistan, Ukraine, Uzbekistan

### Remarks:

The appliances as mentioned under "Types" are suitable for 2<sup>nd</sup> family gases containing up to 20% of Hydrogen gas (H<sub>2</sub>), except for gas groups Lw and Ls.