



Number	18GR0407/03	Replaces	18GR0407/02
Issue date	10-02-2022	Contract number	E 6520
Due date	10-02-2032	Module	B (Type testing)
Report number	170601928	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063CS3928		

EU TYPE EXAMINATION CERTIFICATE (GAR)

Kiwa hereby declares that the condensing central heating boilers, type(s):

Quinta Ace 115, Quinta Ace 115 BL, Quinta Ace 115 PL, Quinta Ace 30, Quinta Ace 45, Quinta Ace 45 BL, Quinta Ace 45 PL, Quinta Ace 55, Quinta Ace 55 PL, Quinta Ace 65, Quinta Ace 65 BL, Quinta Ace 65 PL, Quinta Ace 90, Quinta Ace 90 BL, Quinta Ace 90 PL

Manufacturer

**Remeha B.V.
Apeldoorn, The Netherlands**

meet(s) the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard: EN 15502-1:2012+A1:2015 and EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE



Number	18GR0407/03	Replaces	18GR0407/02
Issue date	10-02-2022	Contract number	E 6520
Due date	10-02-2032	Module	B (Type testing)
Report number	170601928	Scope	(EU) 2016/426 (9 March 2016)
PIN	0063CS3928	Page	1 of 1

APPENDIX TO EU TYPE EXAMINATION CERTIFICATE (GAR)

Manufacturer:

Remeha B.V.

Types:

Quinta Ace 115, Quinta Ace 115 BL, Quinta Ace 115 PL, Quinta Ace 30, Quinta Ace 45, Quinta Ace 45 BL, Quinta Ace 45 PL, Quinta Ace 55, Quinta Ace 55 PL, Quinta Ace 65, Quinta Ace 65 BL, Quinta Ace 65 PL, Quinta Ace 90, Quinta Ace 90 BL, Quinta Ace 90 PL

Appliance types:

B₂₃(P), B₃₃, C₁₃(X), C₃₃(X), C_{43P}(X), C₅₃(X), C₅₃, C₆₃(X), C₉₃(X)

Appliance categories:

I_{2E}(R), I_{2E}(S), I_{2Esi}, I_{2EK}, I_{2H}, I_{3B}/P, II_{2ELL3B}/P, II_{2ELwLs3B}/P, II_{2Esi3B}/P, II_{2H3B}/P, II_{2HS3B}/P, II_{2L3B}/P

Gas groups and supply pressures:

H: 20 mbar; 25 mbar; HS: 25 mbar; E: 20 mbar; E(R): 20 mbar, 25 mbar; E(S): 20 mbar, 25 mbar; Esi: 20 mbar; 25 mbar; K: 25 mbar; L: 25 mbar; LL: 20 mbar; Lw: 20 mbar; Ls: 13 mbar; B/P: 30 mbar; 37 mbar; 50 mbar;

Countries:

Albania, Austria, Belarus, Belgium, Bosnia and Herzegovina, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Liechtenstein, Lithuania, Luxembourg, Macedonia, Malta, Moldova, Montenegro, Norway, Poland, Portugal, Romania, Russia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey, Ukraine, United Kingdom, the Netherlands

Remarks:

- Models 115 are not suitable for gas group Ls
- These appliances are suitable for the mentioned 2nd family gasses containing up to 20% of Hydrogen gas (H₂), except for gas groups Lw and Ls