

EU type examination certificate**EU-Baumusterprüfbescheinigung****CE-0085CM0178**Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Distributor <i>Vertreiber</i>	Remeha B.V. Kanaal Zuid 110, NL-7300 AA Apeldoorn
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Condensing boiler with fan-assisted burner optional with drinking water storage
Model <i>Modell</i>	CALORA TOWER GAS ...
Countries of Destination <i>Bestimmungsländer</i>	AL, AT, BE, BG, BY, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NL, NO, PL, PT, RO, RU, SE, SI, SK, TR, UA
Test Reports <i>Prüfberichte</i>	type testing: 153335a T12/17654 from 20.03.2018 (GWI)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017)

Validity / File no. 21.04.2018 until 12.04.2028 / 17-0731-GEA
Gültigkeit / AZ

12.04.2018 Kö B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.

DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data
Elektrische Daten

230 V AC, 50 Hz, IP21

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E(S)	20/25 mbar	BE	
I2H	20 mbar	LV	
I3P	37 mbar	BE	
II2E3P	20, 29 mbar	LU	
II2E3P	20, 37 mbar	LU	
II2ELL3B/P	20, 50 mbar	DE	
II2ELw3P B/P	20, 37 mbar	PL	
II2ELwLs3P(B/P)	20,20,13, 37 mbar	PL	
II2Esi3P	20/25, 37 mbar	FR	
II2H3B/P	20, 30 mbar	CY, EE, TR	
II2H3B/P	20, 37 mbar	TR	
II2H3P	20, 30 mbar	DK, FI, NO, RO, SE	
II2H3P	20, 37 mbar	CH, CZ, ES, GB, GR, HR, IE, IS, LT, PT, SI, SK	
II2H3P	20, 50 mbar	AT, CH, SK	
II2HM3P	20, 37 mbar	IT	
II2HS3P	25, 30 mbar	HU	
II2L3P	25, 30 mbar	NL	
II2L3P	25, 37 mbar	NL	
II2L3P	25, 50 mbar	NL	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
...15 S DE; ...15SI BE; ...15S EX	nominal heat output: 3,0...14,9 kW heat input (Hi): 3,1...15,0 kW	
...25 S DE; ...25 S BE; ...25SI BE; ...25S EX	nominal heat output: 5,0...24,8 kW heat input (Hi): 5,2...25,0 kW	
...35 S; ...35 S DE; ...35 S BE; ...35SI BE; ...35S EX	nominal heat output: 6,3...34,8 kW heat input (Hi): 6,5...35,1 kW	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
...BE	boiler for BE
...DE	boiler for DE
...EX	for export
...S	boiler for NL
...SI	display Diematic

Hints of Utilization /Remarks
Verwendungshinweise / Bemerkungen

Flue types B23, B23P, B33, C13(x), C33(x), C43(x), C53, C63(x), C83(x) and C93(x): according to installation manual no. 300024416-001-A, 300024417-001-A, 7605048-001-01 and 300026141-001-06

Additional proved countries of destination, appliance categories and supply pressures:

AL, MK: II2H3P (20, 30 mbar)

MT: II2H3P (20, 37 mbar)

BY, RU, UA: II2H3P (20, 30 und 50 mbar)

BG: II2H3P (20, 37 und 50 mbar)

NL: I2EK (20, 25 mbar)

In Albania, Belarus, Macedonia, in the Russian Federation and in the Ukraine the CE-marking will be accepted as conformaty approval if the EU-Gas Appliance Regulation (EU/2016/426) is transferred into national law by Albania, Belarus, Macedonia, the Russian Federation respectively by the Ukraine.