



# HSE Alert

## Worker Fall From Height

Issued: 20/11/2025

### What happened

On Saturday, 13<sup>th</sup> September, Endeavour Energy experienced a safety incident involving one of our workers who fell from a height whilst descending a ladder. The employee was tended to on site by a colleague and transported to hospital for further evaluation. The employee was discharged from hospital later in the evening without significant injuries and is recovering well.

### What has been done

Welfare checks with the worker and the affected work party have been undertaken. Other internal company processes were followed. The incident has been reported to SafeWork NSW and IPART and an investigation has commenced.

### What you need to do

All persons working on or near Endeavour Energy's network are reminded to please follow all safety protocols when Working at Height including, but not limited to;

- Using appropriate fall protection equipment
- Conducting pre-task risk assessments and inspections
- Ensuring ladders and access equipment are stable and fit for purpose
- Maintaining three points of contact when climbing
- Ensuring ladders are tied off at the top and bottom, as well as footed by another worker if the ladder can't be secured
- Reporting any unsafe conditions immediately
- Maintain focus for all 100% moments regardless of the risk type

UNCONTROLLED COPY IF PRINTED

Owner: Sanja Milosavljevic, Head of System Operations  
Approver: Merrilyn Tinsley, Head of Health and Safety  
Expiry Date: 12 months from date of issue  
FSY 0192 May 2023

WSY 0001

Page 1 of 1