

Danish Indoor Climate Labelling

Certificate no. 087



Danish Indoor Climate Labelling hereby certifies that the product group:

H+H Wall systems

H+H Nordics A/S
Skanderborgvej 234
8260 Viby J
Denmark

has been approved and awarded a labelling license

The labelling license is valid through:

14 March 2027

Danish Indoor Climate Labelling

This certificate is subject to annual renewal according to the procedures of Danish Indoor Climate Labelling. Danish Indoor Climate Labelling may withdraw the rights to use this certificate in case the manufacturer does not meet the requirements.

Danish Indoor Climate Labelling

Certificate no. 087

Labelling license holder:

H+H Nordics A/S
Skanderborgvej 234
8260 Viby J
Denmark

Product group:

H+H Wall systems

Testing and labelling criteria

General labelling criteria, 7th edition, 2021,
Ceiling and wall systems, 4th edition, 2018

Date of first issue of license

15 March 2010

Tested product(s)

H+H Multipladen 535

Evaluation of product group

EMISSION CLASS 1

The labelling license covers products considered to be identical with the tested product regarding emission and particle characteristics as specified by the labelling criteria. For a full list of products covered by the labelling license, see Appendix.

The emission class was determined based on the following measured values:

Measured values after 28 days		
TVOC ₂₈	0.08	mg/m ³
Formaldehyde ₂₈	< 0.005	mg/m ³

Sensory evaluation	
Time-value	20 days

Labelling license basis

The tested product(s) shows compliance with the DICL criteria for the present product group:

Emission measured after 3 days		
TVOC	≤	10 mg/m ³
EU CARC 1A and 1B	≤	0.01 mg/m ³

Emission measured after 28 days		
Sum of TVOC and SVOC with LCI	≤	1.0 mg/m ³
EU CARC 1A and 1B	≤	0.001 mg/m ³
R-value	≤	1

Sensory evaluation		
Time-value	≤	100 days

Emission Class 1	TVOC ₂₈	≤	0.5	mg/m ³
	Formaldehyde ₂₈	≤	0.01	mg/m ³
Emission Class 2	TVOC ₂₈	≤	1.0	mg/m ³
	Formaldehyde ₂₈	≤	0.06	mg/m ³
Emission Class 3	TVOC ₂₈	≤	1.0	mg/m ³
	Formaldehyde ₂₈	≤	0.1	mg/m ³

Product information requirements

The holder of the labelling license is required to present the following product information on demand in order to avoid any adverse effects of the product on the indoor air quality in practice: product specifications, guidelines for transport, storage, assembly, cleaning and maintenance.

In the event of any discrepancies in the text arising from translation, the Danish text shall prevail.