

# **Chillventa Specialist Forums 2022** **Chillventa Fachforen 2022**

**CONNECTING  
EXPERTS.**




# Influence of the Dry Cooler Capacity on the Efficiency of Chillers



Hanns Christoph Rauser  
12-10-2022

**CONNECTING  
EXPERTS.**



## Agenda:

- ◆ Introduction: Chiller & Efficiencies
- ◆ Case study, results, energy savings
- ◆ Conclusion
- ◆ Certification by Eurovent Certita Certification
  - How does it work?
  - Heat Exchangers certification programme

- Energy efficiency is currently one of the most important subjects in the HVAC&R industry.
- When using a certified chiller with a separately installed condenser or dry cooler, it is very advisable also to use a certified product in order to reach the maximum total energy efficiency.
- Due to correct performance indications, the certified heat exchanger is selected exactly according to the application and fulfills the requirements. The refrigeration unit runs as expected including energy consuming components such as fans.
- Therefore, correct performance indications for heat exchangers are absolutely essential. They influence the energy efficiency of the entire system.

# INTRODUCTION: CHILLER & EFFICIENCIES

CHILLVENTA

## Liquid Chilling Packages or Chillers

Machine able to produce chilled water

Energy Efficiency Ratio (EER): Ratio of the total cooling capacity to the effective power input of the unit

Seasonal Energy Efficiency Ratio (SEER)

$\eta_{sc}$  (Seasonal space cooling energy efficiency)

# INTRODUCTION: CHILLER & EFFICIENCIES

CHILVENTA

## Use of water-cooled chillers - Efficiency of the solution

An air-cooled chiller: finished product  
(no additional system required to reject heat)



A water-cooled chiller:

- Necessary to add a system able to reject heat
- Combination with a dry cooler




**Efficiency of the solution = Efficiency of the system**



# INTRODUCTION: CHILLER & EFFICIENCIES

CHILVENTA

## Chillers & Heat Pumps



## INTRODUCTION: CHILLER & EFFICIENCIES

CHILVENTA

How to represent the efficiency of the system



EER = Ratio of the total cooling capacity to  
(the effective power input of the unit +  
power consumption of the dry cooler fans)

*Pump power consumption is taken into account during the SEER  
calculation as per EN 14825.*



### Seasonal efficiency of the system

**SEER** - Seasonal energy efficiency ratio: Overall energy efficiency ratio of the unit, representative for the whole cooling season. The seasonal energy efficiency ratio is calculated as the reference annual cooling demand divided by the annual energy consumption for cooling.

After determining the EER values for each part load for a unit with a dry cooler, SEER can be calculated as per EN 14825:2018.

**$\eta_{sc}$**  - Seasonal space cooling energy efficiency: Ratio between the space cooling demand for the cooling season, supplied by a space cooling unit and the annual energy consumption required to meet this demand.

# CASE STUDY

CHILLVENTA

## Hypothesis

### 2 kinds of possible data

- True performance
- Self declaration


self declared data could be anywhere in the data crowd...

### Reliability of the data

- Through yearly testing of samples, data certified by Eurovent Certification Company are more transparent comparable and reliable

### This study is comparing the behavior of systems

- Chiller + dry cooler certified by ECC
- Chiller + dry cooler **NOT** certified by ECC (assuming capacity gap = -25 %)



### Conditions and figures

Cooling capacity = 1143 kW

- Chiller water temperature = 7/12 °C
- Dry cooler water temperature = 30/35 °C


Water-cooled chiller combined with dry cooler

- Noise level 60 dB(A) at 10 m
- AC fans

## CASE STUDY


CHILLVENTA

### Power consumption of water-cooled chiller + dry cooler



Dry cooler fan power consumption may change in a range between 10 % and 20 % according to the different working conditions.

## Conditions and figures



Dry Cooler NOT certified requires that chiller works:

- ❖ at 100 %: higher condensing temperature
- ❖ at 75, 50, 25 %:
  - condensing temperatures are the same
  - fan speed is higher

# CASE STUDY

# CHILVENTA

## SEER and $\eta_{s,c}$ calculation of a unit with a **not-certified** dry cooler

### SEER

Unit Information	
Heat source	Water-to-water
Operating mode	Cooling-only
Application	Air conditioning
Unit capacity control	Variable
Water regulation type	FW/VO
T <sub>designc</sub>	35 °C
P <sub>designc</sub>	1143 kW

Calculation Results	
SEERon	3.78
H <sub>CE</sub>	600 h
Q <sub>c</sub>	685800 kWh
Q <sub>e</sub>	181221 kWh
SEER	3.78
$\eta_{s,c}$	148.3

Unit Performances									
Condition	Outdoor HEX	Indoor HEX	Part load ratio	Cooling dem. (kW)	Declared cap. (kW)	Declared EER	C <sub>d</sub>	CR	EER <sub>bin</sub>
A	30/35 °C	12/7 °C	100%	1143.00	1143.00	2.95	0.90	1.00	2.95
B	26/b °C	a/8,5 °C	74%	842.21	846.00	3.45	0.90	1.00	3.45
C	22/b °C	a/10 °C	47%	541.42	537.00	3.95	0.90	1.00	3.95
D	18/b °C	a/11,5 °C	21%	240.63	240.00	4.20	0.90	1.00	4.20

a: With the flow rate as determined during 'A' test for units with a fixed flow rate. See EN 14825 for further details.

b: With the flow rate as determined during 'A' test for units with a fixed flow rate. See EN 14825 for further details.

Auxiliary Power Inputs and Electricity Consumption			
Paux modes	Hours	Power input (W)	P x h (kWh)
P <sub>toc</sub> : Thermostat-off	659	0	0
P <sub>sb</sub> : Stand by	1377	0	0
P <sub>off</sub> : Off	0	0	0
P <sub>ck</sub> : Crankcase heater	2036	0	0

Bin Calculation									
Condition	Bin	Outdoor air temp.	Hours	Part load ratio	Cooling dem. (kW)	Cooling capacity of the chiller	EER <sub>bin</sub>	Annual cooling demand	Annual electricity cons.
	J	T <sub>j</sub>	h <sub>j</sub>	pI(T <sub>j</sub> )	Pc(T <sub>j</sub> )			h <sub>j</sub> *Pc(T <sub>j</sub> )	h <sub>j</sub> *(Pc(T <sub>j</sub> )/EER <sub>bin</sub> (T <sub>j</sub> ))
	-	°C	h	%	kW	kW	-	kWh	kWh
	1	17	205	5.26%	60.16	61.80	4.20	12332	2936
	2	18	227	10.53%	120.32	121.20	4.20	27312	6503
	3	19	225	15.79%	180.47	180.60	4.20	40607	9668
D	4	20	225	21.05%	240.63	240.00	4.20	54142	12891
	5	21	216	26.32%	300.79	299.40	4.15	64971	15656
	6	22	215	31.58%	360.95	358.80	4.10	77604	18928
	7	23	218	36.84%	421.11	418.20	4.05	91801	22667
	8	24	197	42.11%	481.26	477.60	4.00	94809	23702
C	9	25	178	47.37%	541.42	537.00	3.95	96373	24398
	10	26	158	52.63%	601.58	598.80	3.85	95049	24688
	11	27	137	57.89%	661.74	660.60	3.75	90658	24175
	12	28	109	63.16%	721.89	722.40	3.65	78687	21558
	13	29	88	68.42%	782.05	784.20	3.55	68821	19386
B	14	30	63	73.68%	842.21	846.00	3.45	53059	15379
	15	31	39	78.95%	902.37	905.40	3.35	35192	10505
	16	32	31	84.21%	962.53	964.80	3.25	29838	9181
	17	33	24	89.47%	1022.68	1024.20	3.15	24544	7792
	18	34	17	94.74%	1082.84	1083.60	3.05	18408	6036
A	19	35	13	100.00%	1143.00	1143.00	2.95	14859	5037
	20	36	9	105.26%	1203.16	1202.40	2.95	10828	3671
	21	37	4	110.53%	1263.32	1261.80	2.95	5053	1713
	22	38	3	115.79%	1323.47	1321.20	2.95	3970	1346
	23	39	1	121.05%	1383.63	1380.60	2.95	1384	469
	24	40	0	126.32%	1443.79	1440.00	2.95	0	0
TOTAL			2602					1090302	288285

# CASE STUDY

# CHILVENTA

## SEER and $\eta_{s,c}$ calculation of a unit with a **certified** dry cooler

### SEER

Unit Information	
Heat source	Water-to-water
Operating mode	Cooling-only
Application	Air conditioning
Unit capacity control	Variable
Water regulation type	FW/VO
T <sub>designc</sub>	35 °C
P <sub>designc</sub>	1143 kW

Calculation Results	
SEER <sub>on</sub>	3.97
H <sub>CE</sub>	600 h
Q <sub>c</sub>	685800 kWh
Q <sub>c,e</sub>	172795 kWh
<b>SEER</b>	<b>3.97</b>
<b><math>\eta_{s,c}</math></b>	<b>155.8</b>

Unit Performances									
Condition	Outdoor HEX	Indoor HEX	Part load ratio	Cooling dem. (kW)	Declared cap. (kW)	Declared EER	C <sub>d</sub>	CR	EER <sub>bin</sub>
A	30/35 °C	12/7 °C	100%	1143.00	1143.00	3.10	0.90	1.00	3.10
B	26/b °C	a/8,5 °C	74%	842.21	846.00	3.62	0.90	1.00	3.62
C	22/b °C	a/10 °C	47%	541.42	537.00	4.16	0.90	1.00	4.16
D	18/b °C	a/11,5 °C	21%	240.63	240.00	4.38	0.90	1.00	4.38

a: With the flow rate as determined during 'A' test for units with a fixed flow rate. See EN 14825 for further details.


b: With the flow rate as determined during 'A' test for units with a fixed flow rate. See EN 14825 for further details.

Auxiliary Power Inputs and Electricity Consumption			
Paux modes	Hours	Power input (W)	P x h (kWh)
P <sub>toc</sub> : Thermostat-off	659	0	0
P <sub>sbc</sub> : Stand by	1377	0	0
P <sub>offc</sub> : Off	0	0	0
P <sub>ckc</sub> : Crankcase heater	2036	0	0

Bin Calculation									
Condition	Bin	Outdoor air temp.	Hours	Part load ratio	Cooling dem. (kW)	Cooling capacity of the chiller	EER <sub>bin</sub>	Annual cooling demand	Annual electricity cons.
	J	T <sub>J</sub>	h <sub>J</sub>	p(T <sub>J</sub> )	Pc(T <sub>J</sub> )			h <sub>J</sub> * (Pc(T <sub>J</sub> ))	h <sub>J</sub> * (Pc(T <sub>J</sub> )) / EER <sub>bin</sub> (T <sub>J</sub> )
	-	°C	h	%	kW	kW	-	kWh	kWh
	1	17	205	5.26%	60.16	61.80	4.38	12332	2816
	2	18	227	10.53%	120.32	121.20	4.38	27312	6236
	3	19	225	15.79%	180.47	180.60	4.38	40607	9271
D	4	20	225	21.05%	240.63	240.00	4.38	54142	12361
	5	21	216	26.32%	300.79	299.40	4.34	64971	14984
	6	22	215	31.58%	360.95	358.80	4.29	77604	18081
	7	23	218	36.84%	421.11	418.20	4.25	91801	21610
	8	24	197	42.11%	481.26	477.60	4.20	94809	22552
C	9	25	178	47.37%	541.42	537.00	4.16	96373	23167
	10	26	158	52.63%	601.58	598.80	4.05	95049	23457
	11	27	137	57.89%	661.74	660.60	3.94	90658	22986
	12	28	109	63.16%	721.89	722.40	3.84	78687	20513
	13	29	88	68.42%	782.05	784.20	3.73	68821	18460
B	14	30	63	73.68%	842.21	846.00	3.62	53059	14657
	15	31	39	78.95%	902.37	905.40	3.52	35192	10009
	16	32	31	84.21%	962.53	964.80	3.41	29838	8745
	17	33	24	89.47%	1022.68	1024.20	3.31	24544	7420
	18	34	17	94.74%	1082.84	1083.60	3.20	18408	5745
A	19	35	13	100.00%	1143.00	1143.00	3.10	14859	4793
	20	36	9	105.26%	1203.16	1202.40	3.10	10828	3493
	21	37	4	110.53%	1263.32	1261.80	3.10	5053	1630
	22	38	3	115.79%	1323.47	1321.20	3.10	3970	1281
	23	39	1	121.05%	1383.63	1380.60	3.10	1384	446
	24	40	0	126.32%	1443.79	1440.00	3.10	0	0
TOTAL			2602					1090302	274714



## Conditions and figures



### ❖ With Dry Cooler **NOT certified**:

- Fan power consumption is higher
- System efficiency is lower, specially at high capacity
- **SEER** = 3.78
- $\eta_{sc}$  = 148.3
- **Annual cons.** = 288 MWh

### ❖ With Dry Cooler **certified**

- **SEER** = 3.97
- $\eta_{sc}$  = 155.8
- **Annual cons.** = 275 MWh

***SEER +5.03 % higher and  $\eta_{sc}$  +5.06 % higher !***  
***Annual Electricity Consumption -4.5 % lower !***

### Energy and € differences

-4.5 % difference

City of NÜRNBERG  
(cost 0,30 €/kWh)

Using a product which is  
certified by ECC can mean  
a relevant energy saving  
4070 € / year

## CASE STUDY


# CHILVENTA

**The use of a non certified dry cooler can transform a modern chiller in an old and not efficient unit**




## To put into perspective... 2021 Chiller Market in Europe

Chillers' sales by construction type,  
in units, 2021



Chillers' sales by construction type,  
in kW, 2021



**You can imagine how much money and energy would be saved if the certified dry coolers are used!!**

# Key benefits in one glance and best practice

CHILVENTA

## Easy product selection in HVAC-R

- Direct comparison of competitive products

## Good for customer, good for the planet

- New installations as well as retrofitting
- Less energy consumption as the unit runs as expected to achieve the required performance ⇒ reduced product climate and environmental impact as well as electricity costs
- Task incentives for more energy savings (ex: France)




## In all cases, the best practice is the following

- Good design (avoid oversizing) ⇒ ask for third party certified performances
- Good energy efficiency ⇒ ask for third party certified best classes

## ECC Voluntary labelling for dry coolers

How and by who is labelling prepared?

- ❖ Based on European testing standards (EN1048:2014)
- ❖ Rating prepared by industry
- ❖ We need to cover full range of the market



Meaningful ratings and balanced distribution of classes are the key points

Acc. to Certification Manual art. 318:

A+ < 1 %, A < 5 %, B < 15 %, C < 30 %, D and E > 50 %

## Eurovent Certita Certification in numbers

**44**

Certification  
programmes

**+300K**

Certified products

**+1800**

Tests / year

**24/7**

Performance  
data available  
on website

**+2600**

Certificates  
delivered / year




## Certification Programmes



44 certification programmes

For buildings and homes

## How does it work?



## Zoom on the Heat Exchangers programme

# Scope

Direct  
Expansion  
(Dx) Air  
Coolers  
using HFC

Dx Air  
Coolers  
using CO<sub>2</sub>

Air Cooled  
Condensers

CO<sub>2</sub> Gas  
Coolers

Dry Coolers.

**CERTIFY-ALL PRINCIPLE**

### Certification programme for Dry Coolers

Certified performance items for Dry coolers:

- Standard capacity [kW]
- Fan power input [W]
- Energy Ratio R [-]
- Energy class [-]
- Air volume flow [m<sup>3</sup>/h]
- Fluid side pressure drops [kPa]
- A-weighted sound pressure level [dB(A)]
- A-weighted sound power level [dB(A)]




For dry coolers, the test is carried on according to EN 1048:2014

## Certification programme for Dry Coolers

$$R_{\text{Dry coolers}} = \frac{\text{Capacity @ DT1 = 15K}}{\text{Fan power cons}}$$

Energy class	Energy consumption	Dry coolers
A+	Extremely low	$R \geq 226$
A	Very Low	$169 \leq R < 226$
B	Low	$109 \leq R < 169$
C	Medium	$69 \leq R < 109$
D	High	$37 \leq R < 69$
E	Very high	$R < 37$



EN 1048:2014

**Thank you for your attention !**

**Any question?**

**CONNECTING  
EXPERTS.**

