


# Chillventa Specialist Forums 2022

## Chillventa Fachforen 2022

**CONNECTING  
EXPERTS.**



# How the Digitalisation will Revolutionise Operating Efficiency


- Air Conditioning, Heat Pumps and Refrigeration use 20% of global electricity
- These systems represents 30-60% of electricity in buildings.
- **10-30% savings potential = 2 to 6 % of global electricity**
- **Reduction of peak power**
- **Use building inertia to move load in time**
- **Reduce failures and downtime**

## ClimaCheck Sweden AB

Klas Berglöf

Mobile: +4670 594 95 52


Email: [Klas.Berglof@ClimaCheck.com](mailto:Klas.Berglof@ClimaCheck.com)



# The future will be different and transition has started

- **Digitalisation will change Business as Usual**
  - Most systems have all or most of sensors required for complete performance analyses
  - Equipment owners want to have pay-back on their investments in BMS/BAS/SCADA and IoT
- **Pressure on Energy efficiency and reduction of peak loads is on**
- **Onsite troubleshooting and inspections are inefficient**
  - Experts are not available onsite and it is costly to get them there
  - All technicians/engineers are not experts on everything
  - Analytics makes information of data
  - Thousands of systems can be analysed and benchmarked on component level online
  - Automated Fault Detection and Diagnosis serve competent experts with early warning

# ClimaCheck



# dena award ClimaCheck project to develop Energy performance indicators



- 450 000 Euro project to develop Energy Performance Indicator platform
- Germany has aggressive targets to decrease energy consumption
- **dena** - the German energy agency has identified the need for action
  - In small and medium sized companies that lack in house experts
  - In refrigeration, air conditioning and heat pump systems
- **dena** want to speed up implementation by establishing
  - Energy Performance Indicators “EnPI” for benchmarking of system based on categories
  - A cost-effective web based solution for Small and Medium Sized enterprises “SMEs”
- ClimaCheck has developed solutions for performance analysing and monitoring since 2004 and cooperate with
  - **Kühlanalyse** – German distributor and expert on analysing and optimisation
  - **Idun Real Estate Solutions** – Expert on secure data platforms on RealEstateCore standard

**Wanted** - Test pilots interested in benchmarking their systems



# A global problem need a solution



A world map is centered on the slide, with labels for four regions: Europe, North / South America, Africa, and Asia. Various company logos are placed around the map, corresponding to these regions. The logos include:

- Europe:** AKADEMISKA HUS, NACKA KOMMUN, RISSE, CHALMERSFASTIGHETER, Region Uppsala, ATRIUM LJUNGBERG, Vasakronan, VEOLIA, AstraZeneca, FRESNIUS HELIOS, EDEKA, Transport for London, AMF Fastigheter, and IKEA.
- North / South America:** NREL, Banner Health, Intermountain Healthcare, and Chemours.
- Africa:** V&A WATERFRONT CAPE TOWN and Nampak.
- Asia:** CLP, CLP 中電, Sands Macao, and BBP.

Text on the map: 1000+ systems, 20,000,000+ "data points", Every day"

# Thermodynamic Method = Internal Method

internationally validated and proven - opens the "Black Box"



# Performance analysis

## Crucial information/ KPI's

- **System Efficiency Index – SEI**  
Same KPI's for all buildings that doesn't change continuously as COP/EER or kW/RT.
- Producing business intelligence supporting decision making

## Predictive maintenance

- Detect deviations in performance and functionality instead of "outside the envelope"
- Early Warnings (Fewer alarms)


## Benchmark

### ClimaCheckonline

#### System Information


Plant: [REDACTED]  
Customer: [REDACTED]  
Unit Name: York YK  
Refrigerant: R134A  
Last time in operation: 2020-11-06 12:59  
Values shown for: 2020-11-05 17:08

#### The hour before selected time



#### System Efficiency Index


##### SEI Cool



SEI 1 Cool	43.6 %
Ref Temp. Heat	31.8 °C
Ref Temp. Cool	9.7 °C
COP Heat Ref.	6.63
COP Cool Ref.	5.57
Cap. Heat	1410.4 kW
Cap. Cool	1183.9 kW
Rel. Power Comp. / Nom.	
Power input Comp.	212.6 kW


#### Sub-Efficiencies

##### Refrigerant Cycle n1




Eff Refr. Cycle	87.8 %
Ref Evap.	6.4 °C
Ref Cond.	33.9 °C
Super- heat	0 K
Sub- cool tot.	1.9 K
Press. Ratio	2.85

##### Compressor n2




Comp Eff Isen.	62.2 %
Ref Evap.	6.4 °C
Ref Cond.	33.9 °C
Press. Ratio	2.85
Ref Comp. out	43.5 °C
Super- heat	0 K
Power input Comp.	212.6 kW
Comp. Heat loss	5 %

##### Condenser n4co



Eff 4 Cond.	92.5 %
Cap. Heat Cond	1410.4 kW
SecW Cond in	30 °C
SecW Cond out	33.6 °C
dt Cond. SecW out - in	3.6 °C
SecW Flow	93.61
Ref Cond.	33.9 °C
Appro. Cond. - SecW out	0.3 °C
Ref Exp. Valve in	32 °C
Sub- cool tot.	1.9 K

##### Evaporator n4ev




Eff 4 Evap.	87.3 %
Cap. Cool net	1183.91
SecC Evap in	12.3 °C
SecC Evap out	7 °C
dt Evap. SecC in - out	5.3 °C
SecC Flow	53.31
Ref Evap.	6.4 °C
Appro. SecC out -Evap.	0.6 °C
Ref Comp. in	6.4 °C
Super- heat	0 K



# Guideline establish best practice


## Guidelines for Instrumentation and Data



International  
Energy Agency,  
Annex 52

Click to  
right and left  
to open Guidelines.


## Guidelines for Calculation of uncertainties





Project driven by demand for structured M&V procedures and performance indicators  
for Ground Source Heat pumps/Chiller

But structure generally applicable for verification and benchmarking of vapor compression systems

# Straight forward - but there are hundreds of designs



It is all about making actionable information out of data



# Systems are not stable and do not operate at rating/design

60% of energy overlooked

## Conventional commissioning

*Scheduled maintenance*

Initial balancing ventilation



Initial balancing distribution

## Continuous commissioning

Predictive maintenance

Secondary systems 40%

**AC / Heat Pump Unit 60%**



Measure and Analyse

Verification

Monitor

# Typical Findings

## Common Identified Problems

Controls – not well commissioned – adapted for the site

Refrigerant – shortage or over-charge

Flow balancing – too high or low on secondary media (air/water/brine)

Heat exchangers – fouling of – recirculation of air – corrosion

Fan/pump – high power consumption – under performance

Compressor – damage or wear

Insufficient capacity control – requires VFDs better capacity control

VFD installed but not correctly set-up – not used – not stable

Components changed/upgraded – without review system/controls

# Significant savings achieved

Historical savings structured optimisation	
Supermarkets	20 - 30%
Heat pumps	10 - 30%
Ice rinks	20 - 40%
Industry	10 - 30%
Air Conditioning	10 - 30%




# It is critical to pin-point deviations and optimise

Bad COP 3.76

Same chiller – same supply temp

Good COP 5.02



### System Efficiency Index

SEI Cool

SEI 1 Cool	42.4 %
Ref Temp. Heat	31.5 °C
Ref Temp. Cool	7.8 °C
COP Heat Ref.	5.95
COP Cool Ref.	5.02
Cap. Heat	395.2 kW
Cap. Cool	333.4 kW
Rel. Power Comp. / Nom.	0.63
Power input Comp.	66.4 kW

### Sub-Efficiencies

#### Refrigerant Cycle n1

Eff Refr. Cycle	85.3 %
Ref Evap.	4.1 °C
Ref Cond.	36.4 °C
Super- heat	3.5 K
Sub- cool tot.	1.3 K
Press. Ratio	2.72

#### Compressor n2

Comp Eff Isen.	68.5 %
Ref Evap.	4.1 °C
Ref Cond.	36.4 °C
Press. Ratio	2.72
Ref Comp. out	50.5 °C
Super- heat	3.5 K
Power input Comp.	66.4 kW
Comp. Heat loss	7 %

#### Condenser n4co

Eff 4 Cond.	84.9 %
Cap. Heat Cond	395.2 kW
SecW Cond in	30.6 °C
SecW Cond out	32.4 °C
dt Cond. SecW out - in	1.8 °C
SecW Flow	52.46
Ref Cond.	36.4 °C
Appro. Cond. - SecW out	4 °C
Ref Exp. Valve in	35.1 °C
Sub- cool tot.	1.3 K

#### Evaporator n4ev

Eff 4 Evap.	87.5 %
Cap. Cool net	333.4
SecC Evap in	9.6 °C
SecC Evap out	6 °C
dt Evap. SecC in - out	3.7 °C
SecC Flow	21.8
Ref Evap.	4.1 °C
Appro. SecC out -Evap.	1.8 °C
Ref Comp. in	7.7 °C
Super- heat	3.5 K


# If you cannot measure it - you cannot control it

- Understanding of the entire system necessary
- Analysing performance and controls is the key

State of the art CO2 rack with one variable speed compressor




# Supermarket rack - erratic controls



# Chiller plant 50% (141 586 kWh) saving May-August 2022

	Baseline energy signature (blue line)	Energy consumption post (grey bars)	Difference in consumption
May	25 974 kWh	6 027 kWh	-19 947 kWh (-77%)
June	61 403 kWh	25 389 kWh	-36 014 kWh (-58%)
July	82 008 kWh	46 444 kWh	-35 564 kWh (-43%)
Aug	111 042 kWh	60 981 kWh	-50 061 kWh (45%)
Total	280 427 kWh	138 841 kWh	-141 586 kWh (-50%)

Energy in Interval	636800 kWh 0 kgCO2	636800 kWh 0 kgCO2	0 kWh 0 kgCO2
Stat signature		169843 kWh	
PreOpt signature		806412 kWh	
Nominal signature		0 kWh	



**Graph 12 months (24 hour values)**

Yellow line = ambient temperature

Blue line = expected consumption with baseline performance


Red line = Post measure energy signature (from May so no low ambient data yet)

Grey bars = compressor energy per 24 hours


# Before (2021) and post corrective measures (2022)

Controls stabilised – **no more tripping** of screw chillers

Before



After



Red – condenser capacity

Blue - cooling capacity


Grey - power



# Chiller killer

## Start/stop

- Oil carry over
- Compressor trips
- Increased wear
- Lousy efficiency



We see hundreds off these systems!


# The impact of an optimised system

“Indirect leak detection”

Energy efficient is also reliable

10-30% Reduced energy consumption

Fewer breakdowns



# Indirect leak detection


Leaks are difficult to detect with gas warning detectors

- gas is only detectable near leak and is then dispersed and carried away with ventilation air.

Indirect leak detection is often more reliable and cost effective

- ClimaCheck online offer “indirect leak detection”.
- Leaks are detected by deviation in
  - Subcool
  - Superheat
  - Evaporation
  - Increase start/stopp
  - Energy signature

# Optimisation should be verified and monitored



Questions



now or visit our Booth 9:360

**CHILLVENTA**

**CONNECTING  
EXPERTS.**

