

SUPPORT SYSTEM

- 1. All suspension-rigging points can support 4 times the intended load, and are tied back.
Yes _____ No _____ Comments _____
- 2. The structure is able to support the loads (parapet wall, roof etc.).
Yes _____ No _____ Comments _____
- 3. Suspension lines terminated w/ shackle, thimble, 3 J-clamps, spaced the same as the stirrups and the wire rope is long enough to reach the bottom of the drop.
Yes _____ No _____ Comments _____
- 4. Outriggers are rated for the application, correct # of counter-weights attached, and secured.
Yes _____ No _____ Comments _____
- 5. Parapet clamps and roof hooks are properly tightened and seated to the wall correctly.
Yes _____ No _____ Comments _____
- 6. All pipe scaffolds or outrigger supports are assembled per manufacturer's instructions.
Yes _____ No _____ Comments _____
- 7. Tiebacks are properly configured, secured, and tied to suitable anchorage points.
Yes _____ No _____ Comments _____
- 8. Power cord has strain relief at source; all edges it passes over are padded.
Yes _____ No _____ Comments _____

SUSPENDED EQUIPMENT

- 1. Operators have been briefed on equipment and are qualified to use it safely.
Yes _____ No _____ Comments _____
- 2. Lifelines are independently tied back to suitable anchorage and abrasion protection provided.
Yes _____ No _____ Comments _____
- 3. Harnesses and lanyards are in good condition, as well as rope grabbers, snap hooks, and fittings.
Yes _____ No _____ Comments _____
- 4. All parts (platform connections, toe boards, debris control netting, guardrails) of the scaffold have been properly installed and tightened with the correct bolts.
Yes _____ No _____ Comments _____
- 5. Hoists are in proper operating condition per manufacturer's recommendations.
Yes _____ No _____ Comments _____
- 6. Have possible hazardous conditions been reviewed for:
Power Lines? Yes _____ No _____ Wind? Yes _____ No _____
Obstructions? Yes _____ No _____ Other? Yes _____ No _____
- 7. The suspended scaffold appears to be operating properly.
Yes _____ No _____ Comments _____

Reviewed By: _____ Signature: _____