



Sidewalk Bridge Inspection Checklist

1. Is there debris on top of the sidewalk shed? Yes ___ No ___
2. Are there materials stored on top of the sidewalk shed? Yes ___ No ___
3. Are there any gaps or openings on the sidewalk shed? Yes ___ No ___
4. Are there any parapet panels missing on the sidewalk shed? Yes ___ No ___
5. Is the solid barrier fence or chain link fence with debris netting missing/damaged? Yes ___ No ___
6. Are the view panels in the solid barrier fence missing/damaged? Yes ___ No ___ N/A ___
7. Have tamper proof nuts have been installed at the sidewalk shed? Yes ___ No ___
8. Have the bolts under the sidewalk shed been padded/covered? Yes ___ No ___
9. Have nails been installed in the mudsills? Yes ___ No ___
10. Are there any cracked or damaged mudsills? Yes ___ No ___
11. Are any lights under the sidewalk shed broken or blown out? Yes ___ No ___
12. Are the vandal proof cages missing or damaged? Yes ___ No ___
13. Is the electrical conduit under the sidewalk shed damaged or in need of repair? Yes ___ No ___
14. Is the required signage posted on the sidewalk shed? Yes ___ No ___
15. Is all cross bracing in place and secure? Yes ___ No ___
16. Has a Daily log of Sidewalk Shed inspections been maintained? Yes ___ No ___
17. Is the Professional Engineer's letter of inspection for the sidewalk shed current and up to date? *Note* PE inspections are due every 6 months or anytime a sidewalk shed has been damaged or displaced. Yes ___ No ___